






**HEALTH DEPARTMENT
NEW DELHI MUNICIPAL COUNCIL
PUBLIC HEALTH LABORATORY, AMRIT BHAWAN
CHANAKYA PURI, NEW DELHI-110021**

1. Name of sender:- Sanskriti School, (NOT Collected by the Lab. Staff.)
 2. Address of sender:- Dr. S. Radhakrishnan Marg, Chanakya-Puri, New-Delhi.
 3. Date of receiving:- 31/8/2017. 5. Sealed Sample (Yes/No):- No.
 4. Dispatch No. & Date:- 2017/08/7440-7441, dt. 7/8/2017.

**DRINKING WATER TESTING REPORT
ESSENTIAL PHYSICO-CHEMICAL AND BACTERIOLOGICAL ANALYSIS**

S.N	Location, date & Time of sample collection site	Colour (Pt-Co scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (mg/L)	TDS Mg/L	Iron (as Fe Mg/L)	Chloride (as Cl Mg/L)	Residual Free Chlorine (Mg/L)	Caliform org MPN / 100 ml	E. Coli MPN / 100 ml
1.	Under Ground Tank	<5	Unobjectionable	<2	7.2	38	131	<0.1	22	0.5	Nil	—
2.	Water Geyser Tap	<5	Under	<2	7.2	46	142	<0.1	26	Nil	Nil	—
3.												
4.												
5.												
Permissible Limits Acceptable		5 Max	Agreeable	1 Max.	6.5 to 8.5	200 max.	500 max	0.3 max	250 max	0.2 min mg/l	≤10	Nil
Rejection able Beyond		15	Agreeable	5	no relaxation	600	2000	no relaxation	1000	1	≥10	Nil

Remarks:- With respect to above tests, all the above samples ~~except~~ except Sr. no. 3 can/can not be considered fit for drinking purposes in absence of alternative sources.

 **Chemist**
 **K. K. DAS**
 Bacteriologist
 Public Health Laboratory
 **Lab Technician**

Note:- i) Water sample will be destroyed after testing unless otherwise specified by party.
 ii) If the sample is not collected by our PHL staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
 iii) This test report is not valid for any legal proceedings.